


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015

Ref. A.C.W.A.(South)/Paid/2022-23/P27-28/C/hallan no 79 dt 30.05.22

S. No 8015

Date: 15.06.22

M/S DEV SAMAJ MODERN SCHOOL NO 2
OKHLA (SUKHDEV VIHAR)
NEW DELHI - 110025

S.N	Characteristics	Unit	Acceptable Limit	Permissible Limit	Test Method	TAP KITCHEN G.F.	DRINKING POINT BACKSIDE OF CLASS XI A
Table 1: Physical Examination							
1.	Clarity	Unit	5	15	IS 3025 Part-4	Clear	Clear
2.	Odour	---	Agreeable	Agreeable	IS 3025 Part-5	No. Obj.	No. Obj.
3.	Turbidity	NTU	1	5	IS 3025 Part-10	1.92	2.17
4.	pH Value	---	6.5-8.5	No relaxation	IS 3025 Part-11	7.7	7.7
5.	Conductivity	µmho/cm ²	---	---	---	311	311
6.	Total Dissolved Solids	mg/L	500	2000	IS 3025 Part-16	202	202
Table 2: CHEMICAL EXAMINATION							
1.	Phenolphthalein Alkalinity	mg/L	---	---	---	NIL	NIL
2.	Total Alkalinity (as CaCO ₃)	mg/L	200	600	IS 3025 Part-23	94	96
3.	Total Hardness (as CaCO ₃)	mg/L	200	600	IS 3025 Part-21	120	124
4.	Carbonate hardness	mg/L	---	---	---	94	96
5.	Non- Carbonate Hardness	mg/L	---	---	---	26	28
6.	Calcium Hardness	mg/L	---	---	---	86	82
7.	Magnesium Hardness	mg/L	---	---	---	34	42
8.	Ammonia (as Total N)	mg/L	0.5	No relaxation	IS 3025 Part-34	ND	ND
9.	Nitrite (as N)	mg/L	---	---	---	ND	ND
10.	Nitrate	Mg/L	---	45.0	IS 3025 Part-34	4.35	4.6
11.	Sulphate (as SO ₄)	mg/L	200	400	IS 3025 Part-24	34	33
12.	Chloride (as Cl)	mg/L	250	1000	IS 3025 Part-40	24	26
13.	Iron	Mg/l	---	1.0	IS 3025 Part-53	0.06	0.4
14.	Fluoride	mg/L	1.0	1.5	IS 3025 Part-60	0.4	32.8
15.	Calcium (as Ca)	mg/L	75	200	IS 3025 Part-57	34.4	10.08
16.	Magnesium (as Mg)	mg/L	30	100	IS 3025 Part-46	8.16	0.56
17.	Free Residual Chlorine	mg/L	0.2	1	IS 3025 Part-26	0.62	---

REMARKS :- AS PER BIS-10500:2012 On the basis of tested parameters the both sample result are within permissible limit. Subject to Bacteriological analysis result.

Assistant Chief Water Analyst
Delhi Jal Board (A Govt. of Delhi)
Zonal Laboratory (South)
W.W. Okhla New Delhi - 110 025
ACWA (SOUTH)

CHEMIST

ACHEMIST

Copy to:-
1 CWA(W&S)-III
2 Office Copy



DEV SAMAJ MODERN SCHOOL No. 2

OKHLA (SUKHDEV VIHAR) NEW DELHI-110025

No. DS/MC/ND/2/2023/2672

Date: 29.08.2023

To


The Health Officer
Health Department
MCD (Lajpat Nagar)
Central Zone, New Delhi.

Sub: Issuance of Health Certificate.

Dear Sir/Madam,


This is to inform you that we, Dev Samaj Modern School, Sukhdev Vihar, New Delhi is a recognized Educational Institution from Pre-School to Class XII with so many students. We have a strength of 2350 students and a well-planned sanctioned Building with pucca structure. Our Health certificate was expired so we hereby request you to kindly issue a fresh Health certificate.

Warm Regards,


Manoj Madaan

Principal

Principal
Dev Samaj Modern School No. 2
Okhla, (Sukhdev Vihar)
New Delhi - 110 025
Recognised

Received

6/9/23

Encl: 1. Copy of Fire NOC

2. Copy of last Health Certificate
3. Strength of Students and Staff
4. Copy of Electricity Bill
5. Copy of Water Bill
- 6.

OFFICE OF THE DEPUTY HEALTH OFFICER, CENTRAL ZONE
JAL VIHAR, SHIV MANDIR MARG, NEW DELHI-24
SOUTH DELHI MUNICIPAL CORPORATION

No:DHOC/NZ/2018/D- 1307

Dated: 30-11-18

HEALTH CERTIFICATE


1. Name of the school: - Dev Samaj Modern School No-2
2. Address of the school: - Okhla (Sukhdev Vihar) New Delhi-25
3. Shift : Morning
4. No. of student: Boys : 1162 Girls: 1097 Total: 2259
5. No. of staff: Gents:07 Ladies:73 Total: 80

6. Accommodation provided are as under:-

- Floor areas in the classrooms are sufficient.
- Classrooms are ventilated and properly lighted.
- Classrooms are kept neat and clean.
- Building/Classrooms do not require white wash.
- Drinking water is wholesome .
- Latrine arrangement is sanitary.
- Number of Latrines and Urinals are sufficient.
- Separate toilet arrangement for Boys & Girls is exist.
- Separate toilet arrangement for staff is exist.
- The overall facilities are adequate.

Remark:

This certificate is valid up to one year from date of issued this certificated has not bearing on any kind of fire safety, structure stability and unauthorized construction and structure stability.


Dy. Health Officer
Central Zone
Dy. Health Officer
Central Zone S.D.M.C